

**City of Nitro**  
2009 20th Street  
Nitro, WV 25143  
304-755-0703

## Footings

### **Footings**

Footings don't bear on frozen soil.

N/A    Pass    Fail

Reinforcement thoroughly clean of loose scale, rust, ice, mud, oil or other deleterious coatings.

N/A    Pass    Fail

Footings project beyond the face of the foundation wall at least 2 inches, but not more than the thickness of the footing.

N/A    Pass    Fail

Footings for masonry chimneys are a minimum of 12 inches thick

N/A    Pass    Fail

Footings are level or stepped if the ground slopes more than 1 foot in 10 feet.

N/A    Pass    Fail

Reinforcement steel is spliced per approved plans with two ties per lap

N/A    Pass    Fail

Steel reinforcement is properly placed and is the correct grade.

N/A    Pass    Fail

Footings are constructed per the approved plan

N/A    Pass    Fail

All loose soil, mud,, or water is removed from the bottom of the footing. Debris, water and/or ice removed from spaces to be occupied by concrete

N/A    Pass    Fail